

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE		PAGE OF PAGES 1	
2. AMENDMENT/MODIFICATION NO. 0004		3. EFFECTIVE DATE 1 Mar 2001		4. REQUISITION/PURCHASE REQ. NO. W26GLG-0340-9411		5. PROJECT NO.(If applicable)	
6. ISSUED BY CONTRACTING DIVISION US ARMY ENGR DIST NORFOLK ATTN: CENAO-CT 803 FRONT STREET  NORFOLK, VA 23510-1096		CODE E4P0000		7. ADMINISTERED BY (If other than item 6)  <b>See Item 6</b>		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. DACA65-01-B-0004	
				X		9B. DATED (SEE ITEM 11) 17 Jan 2001	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of _____ <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended.							
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the document; (b) By acknowledging receipt of this amendment on each copy of the offer or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO RECEIVE AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>							
A.THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B.THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C.THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D.OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) AMENDMENT NO. 0004 to DACA65-01-B-0004, Renovate NCO Qtrs, Fort McNair, Washington, DC The attached clarifications are issued for your use on subject project.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) DEBORA S GRAY / ADDED BY SUMI			
15B. CONTRACTOR/OFFEROR  _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED  18-Jul-2000	

DACA65-01-B-0004

CLARIFICATIONS ISSUED WITH AMENDMENT NO. 0004

Specification Section 01050 – “Job Conditions”; Paragraph 1.11, last sentence should be changed to read: “The Contractor must request approval to work on weekends and Federal holidays at least five (5) working days prior to.

Specification Section 01050 – “Job Conditions”; the following paragraph is to be added:

“1.12 CONSTRUCTION PHASING

Two buildings shall be made available to the contractor at the time of Notice to Proceed. Based on the Contractors proposed schedule, an additional building, shall be made available when those two are complete and then the fourth building will be made available at the completion of the third.”

Specification Section 06200 – “Finish Carpentry”; Paragraph 2.1, the first sentence should read: “The Contractor may use the millwork shop at the U.S. Disciplinary Barrack, Fort Leavenworth...” The recommendation to use the Ft Leavenworth Millwork Shop was a request of the Fort Myer Military Community as a cost savings measure. The drawings state that the contractor “MAY” use the Disciplinary Barrack’s Millwork Shop. It is a recommendation, and is not mandatory.

Specification Section 08550 – “Wood Windows”; Paragraph 1.2, this paragraph should read: “Windows shall be of the type and size indicated. The windows may be fabricated by the Millwork Shop at the U. S. Army Disciplinary Barracks, Fort Leavenworth. The design and construction of the sashes shall be replicas of the sashes that are removed from the quarters.” The recommendation to use the Ft Leavenworth Millwork Shop was a request of the Fort Myer Military Community as a cost savings measure. The drawings state that the contractor “MAY” use the Disciplinary Barrack’s Millwork Shop. It is a recommendation, and is not mandatory.

The storm sewer runs parallel to 4<sup>th</sup> Avenue and is on the opposite side of the street. Eight storm laterals are required (2 for each building), each approximately 120 feet long. The existing storm sewer is shown on the Fort McNair Utility Drawings to be 6” Reinforced Concrete in front of Quarters 23 A&B and as 6” Terracotta in front of Quarters 26 A&B.